



This is to certify that

Protective Treatment XM92/M24

supplied by



A & I COATINGS (UK), UNIT 4 TRANSCENTRAL, BENNET ROAD,
READING, RG2 0QX

has been independently tested by

SOCOTEC

Derwent House, Bretby Business Park, Ashby Road,
Burton on Trent DE15 0YZ

and found to satisfy the requirements of

Network Rail Specification NR/L3/CIV/039

Steel blast-cleaned to surface standard Sa2½ (BS EN ISO 8501-1)

7.1.5 Vitreset V115 Aluminium

125µm mdft

7.1.7 Vitreset V116

125µm mdft

7.3.3 Vitreflon FEVE V195

50µm mdft

Certificate No: **XM92/M24 – 207**

Minimum Expected Service Life:

25 years: Blast Cleaned Steelwork

Formulations Review Date: **03rd November 2025**

Authorised by:

A handwritten signature in blue ink, appearing to read 'R. Emery'.

Ryan Emery
Operations Manager, Coatings

Date: **03rd November 2020**